



Old Teal Flat Communal Wastewater Management System (CWMS) Maintenance Information Sheet

Your property is connected to the Old Teal Flat CWMS. Old Teal Flat is a gravity sewer system which means that there is no septic tank or pump chamber located on your property. The connection to your property is a IP 100mm PVC near boundary.

How does the system work?

The sewerage flows (solids and liquids) from the house through a sewer pipe to a communal pump chamber located on common land. Once the sewerage inside the pump chamber reaches a certain level inside the pump turns on and grinds up the sewerage which is then pumped to the treatment plant. The treatment plant then separates the solids from the liquids through a large septic tank and the liquid (effluent) is then aerated, treated with chlorine and pumped to an irrigation site located above the floodplain.

What should not be put down the drains (toilet, sink or hand basins)

- Any stormwater, including roof and rain water tank overflow and surface drainage waters
- Any backflush waters from a swimming pool or water softener
- Any discharge or backflush from a spa bath/pool in excess of 680 litres capacity
- Any sanitary napkins, clothing or plastic material or liner
- Any trade waste
- Any petrol or other flammable or explosive substance whether solid, liquid or gaseous
- Any disinfectant or deodorant, antiseptic or germicide powder or fluid, unless specifically stated to be suitable for use in a septic tank.

Council CWMS Maintenance Officers have attended numerous blockages/pump burn outs in the past to find that people have flushed sanitary products, nappies, clothing and the like down the drains.



INFORMATION SHEET 65

This is a photo showing a build up of sanitary products and nappies jamming both valves in the pump ultimately causing the pump to burnout beyond repair. The cost to replace this pump was taken from the maintenance fund for the respective CWMS.

If you are having problems with your drains i.e. they appear to be blocked please contact the CWMS Maintenance Officer on 0428 813 438.

If you have any other questions relating to the Old Teal Flat CWMS, please feel free to contact the CWMS Maintenance Officers or the Environmental Health Officer at the Cambrai Office on 8564 6020.



Mid Murray Council

Phone: 8564 6020

Fax: 8569 1931

Main Street, Cambrai

49 Adelaide Road, Mannum

Fourth Street, Morgan

E-mail: postbox@mid-murray.sa.gov.au

Web: www.mid-murray.sa.gov.au

PO Box 28, Mannum SA 5238



This property is connected to a communal wastewater disposal scheme (sewer system).

Please **do not** dispose of the following into the toilet, basin, bath or shower:-

- sanitary napkins/tampons
- non biodegradable products
 - disinfectants/bleach
 - medical dressings
 - disposable nappies
 - clothing/plastics.

All of these items have the potential to cause blockages in the sewer system.



This property is connected to a communal wastewater disposal scheme (sewer system).

Please **do not** dispose of the following into the toilet, basin, bath or shower:-

- sanitary napkins/tampons
- non biodegradable products
 - disinfectants/bleach
 - medical dressings
 - disposable nappies
 - clothing/plastics.

All of these items have the potential to cause blockages in the sewer system.